



ORDER FOR JOINT OR IDENTICAL POLE LOCATIONS

By the Select Board of Otis, Massachusetts:

Notice having been given and a public hearing held, as provided by law, IT IS HEREBY ORDERED THAT:

NSTAR ELECTRIC COMPANY DBA EVERSOURCE AND VERIZON NEW ENGLAND, INC. be and they are hereby granted joint or identical locations for and permission to construct and maintain a line of poles and their respective wires and cables to be placed thereon, together with such sustaining and protecting fixtures as said Companies may deem necessary, thereon, together with such sustaining and protecting fixtures as said Companies may deem necessary, in the public way hereinafter referred to, as requested in petition of said Companies dated the 24th day of April, 2026.

All construction under this order shall be in accordance with the following conditions: Poles shall be of sound timber, and reasonably straight, and shall be set substantially at the points indicated upon the plan marked **22231806** filed with and made a part of said petition. There may be attached to said poles by said EVERSOURCE not to exceed 18 wires and 2 cables, and by VERIZON NEW ENGLAND INC. not to exceed 40 wires and 4 cables, and all of said wires and cables shall be placed at a height of not less than 18 feet from the ground at highway crossings, and not less than 12 feet from the ground elsewhere.

The following is the public way along which the poles above referred to may be erected, and the number of poles which may be erected thereon under this order:

Location & Reason – Town Hill Road, Otis

Eversource is petitioning to install 2 new poles on Town Hill Road, Otis:

- 3) Install one jointly owned P#41/1E to be located approximately one hundred twenty-five (125) feet westerly from existing P#41/1.
- 4) Install one jointly owned P#41/3M to be located approximately one hundred seventeen (117) feet southerly from existing P#41/3.

These new poles are required to support new three phase conductors where current span length is excessive. This work is part of a larger reliability project reducing outages on this circuit. Please refer to the attached sketch.

Also, that permission be and thereby is granted to each of said Companies to lay and maintain underground laterals, cables and wires in the above or intersecting public ways for the purpose of making connections with such poles and buildings as each may desire for distributing purposes.



Legend:
 Existing Joint Pole: 
 Proposed Joint Pole: 

Purpose and Description:
 Eversource is petitioning to install 2 new poles on Town Hill Rd Otis.
 New pole 41/1E is 125' from existing pole 41/1 in a westerly direction.
 New pole 41/3M is to be set 117' in a southerly direction from existing pole 41/3. These new poles are required to support new 3 phase conductors where current span length is excessive. This work is part of a larger reliability project reducing the outages on this circuit.

EVERSOURCE

CITY/TOWN: Otis

STREET: TOWN HILL RD